

# ***PRELIMINARY RESULTS OF THE HAWAII KALINA CYCLE® FEASIBILITY ANALYSIS***

## **Innovative Energy Systems Workshop**

**Honolulu, Hawaii  
March 19 – 20, 2003**

**Sponsored by:  
State of Hawaii-  
Department of Business, Economic Development, and  
Tourism**



# ***PRELIMINARY RESULTS OF THE HAWAII KALINA CYCLE® FEASIBILITY ANALYSIS***

- **Introduction**
  - What is Kalina Cycle?
  - Comparison to Rankine Cycle
- **Historical Applications**
  - California, Iceland & Japan
- **Identification of Promising Hawaii Applications**
- **Conclusions**




# The Kalina Cycle®

- **Binary Energy Conversion Cycle which uses Ammonia/Water Mixture as the Working Fluid**
- **Variable Mixture (Concentration Changes Throughout the Cycle) - Allows Working Fluid to Efficiently Match the Characteristics of the Resource**

**Ideal for Low Temperature/Bottoming  
Cycle Applications**



# Simplified Kalina Cycle®




# **Ammonia/Water Safety Concern?**

- **Needs to be Used Carefully**
  - **Not Classified as Hazardous**
- **Less Hazardously Flammable than more Conventional Working Fluids**
- **Comparatively Environmentally Benign**
- **Ammonia Vents Easily, is Self-  
Alarming**




# Single Working Fluid Thermodynamic Limitation




# Simplified Comparison of Rankine Cycle to Kalina Cycle<sup>®</sup>

## Rankine Cycle



## Kalina Cycle<sup>®</sup>





# Operational Kalina Cycle<sup>®</sup> Plants

Courtesy: Exergy

**3.5 MW Kalina Cycle<sup>®</sup> Plant  
Canoga Park, CA**



**2 MW Kalina Cycle<sup>®</sup> Plant  
Husavik, Iceland**

Courtesy: Exergy






# **Husavik Geothermal Plant**

## **“First Two Years”**

- **Demonstrated High Reliability  
(Availability Rated in the High 90%)**
- **Operates Successfully Largely  
Unattended**
- **Proved to be Quiet, Sturdy with no  
Odor**



# Energy Generation by Source, 1999



# Ten Largest Plants by Generating Capacity, 1999

<b>Plant</b>	<b>Primary Energy Source(s)</b>	<b>Operating Company</b>	<b>Net Summer Capability (MW)</b>
1. Kahe	Petroleum	Hawaiian Electric Co.	582
2. Waiau	Petroleum	Hawaiian Electric Co.	457
3. Kalaeola Co-gen	Petroleum	Kalaeloa Partners LP	261
4. AES Hawaii, Inc.	Coal	AES Hawaii, Inc.	189
5. Maalaea	Petroleum	Maui Electric Co.	168
6. Honolulu	Petroleum	Hawaiian Electric Co.	100
7. Port Allen	Petroleum	Kauai Island Utility Co-op	97
8. H-Power	Waste	DFO Partnership	61
9. Hawaiian Com& Sugar	Coal	Hawaiian Coml& Sugar	58
10. W H Hill	Petroleum	Hawaiian Electric Light Co.	35

Source: Energy Information Administration



# Residues/Pollutants/Effects (qualitative)

	Coal	Oil	Natural Gas	Biomass/ Waste	Nuclear Energy	Solar Energy
CO						
CO <sub>2</sub>						
C <sub>n</sub> H <sub>m</sub>						
NO <sub>x</sub>						
SO <sub>2</sub> (Plaster)						
Dust (soot)						
Ash						
Radioactivity						
Heavy Metals						
Waste Heat						
Material Intensity						
Albedo						
Water Vapor						



# How Much Waste Heat in Hawaii?

- ~ 9 billion  $\text{kW}_h/\text{yr}$  Electricity from Fossil Fuels  
(Hawaii Data Book)
- Conservative Estimate:
  - From Stack Gases: ~ 356 million  $\text{kW}_h/\text{yr}$
  - From Cooling Water: ~ 534 million  $\text{kW}_h/\text{yr}$
  - **Total: ~ 890 million  $\text{kW}_h/\text{yr}$  (~10% of Total Production!)**

**The Waste Heat Potential in Hawaii is Quite Significant!**



# Petroleum/Diesel Power Plants

Courtesy: HECO

**Maalea Power Plant - Maui**




**Kahe Power Plant - Oahu**

Courtesy: MECO





# Simplified Conceptual Flow Diagram for Diesel Combined Cycle





# **Peak Design Capacity for Diesel Combined Cycle / Bottoming Cycle Depends Upon:**

- **Diesel exhaust gas temperature and flow**
- **Fuel sulfur content (limits the min. stack temp.)**
- **Type of cooling available (water or air cooled)**
- **Capacity of diesel generating station**
- **Site ambient conditions**
- **Diesel back pressure requirements**
- **Bottoming cycle design**



# Design Capacity Comparison: Kalina Cycle® vs. Rankine Steam Bottoming Cycle

## First Case Study:

*Kohinoor Energy Ltd. – Pakistan*

8x Wartsila 18V46 diesel units

- Existing Rankine Bottoming Cycle =  $\sim 8 \text{ MW}_{\text{net}}$
- Initial Kalina Cycle® Design =  $\sim 13.3 \text{ MW}_{\text{net}}$  (+66%)
- Optimized Kalina Cycle Design =  $\sim 16.0 \text{ MW}_{\text{net}}$  (+100%)

## Second Case Study:

*Kohinoor Energy Ltd. – India*

4x Wartsila 12V46 diesel units

- Design Rankine Bottoming Cycle =  $\sim 1.87 \text{ MW}_{\text{net}}$
- Kalina Cycle® Design =  $\sim 3.24 \text{ MW}_{\text{net}}$  (+73%)



# **Case Study Example: Turkey**

## **Basic Assumptions**

- **100 MW capacity (PPA ~ 876 million kWh/yr)**
- **Man B&W 18-V-48/60 diesel unit (18.39 MW)**
- **Three competing scenarios:**
  - **7 DG units, no bottoming cycle, one DG in standby**
  - **6 DG units, no bottoming cycle, no DG standby**
  - **6 DG units, Kalina Bottoming Cycle<sup>®</sup> (11 MW), no DG standby**



# **Case Study: Turkey**

## **Basic Assumptions (con.)**

- **Capital Costs**
  - DG Station (\$650/kW)
  - Kalina Cycle<sup>®</sup> (\$1200/kW)
- **O&M Costs**
  - DG Station (\$0.01/kW<sub>hr</sub>)
  - Kalina Cycle<sup>®</sup> (\$0.005/kW<sub>hr</sub>)
- **Fuel Costs (\$0.20/kg)**



# Case Study Summary

<u>Comparison/ Analysis</u>	<u>6 DG &amp; KCC</u>	<u>6 DG Only</u>	<u>7 DG Only</u>
Annual Generation	876 million kW <sub>hr</sub>	835 million kW <sub>hr</sub>	876 million kW <sub>hr</sub>
Annual Gross Revenue	56.94 \$million	54.3 \$million	56.9 \$million
Annual Fuel Cost	28.47 \$million	29.85 \$million	31.36 \$million
Annual Lube Oil Cost	1.00 \$million	1.04 \$million	1.10 \$million
Annual O&M Cost	8.32 \$million	8.35 \$million	8.76 \$million
<b>Total Operating Cost (\$/yr)</b>	<b>37.78 \$million</b>	<b>39.25 \$million</b>	<b>41.22 \$million</b>
Total Operating Cost (\$/kW <sub>hr</sub> )	0.043 \$/kW <sub>hr</sub>	0.047 \$/kW <sub>hr</sub>	0.047 \$/kW <sub>hr</sub>
Capital Charge	0.015 \$/kW <sub>hr</sub>	0.013 \$/kW <sub>hr</sub>	0.014 \$/kW <sub>hr</sub>
Total Generation Cost (\$/kW <sub>hr</sub> )	0.058 \$/kW <sub>hr</sub>	0.060 \$/kW <sub>hr</sub>	0.061 \$/kW <sub>hr</sub>
<b>Gross Operating Profit</b>	<b>19.16 \$million</b>	<b>15.05 \$million</b>	<b>15.72 \$million</b>
Kalina Cycle Payback Period	--	3.2 years	0.4 years
<b>Simple Return on Investment</b>	<b>22.5%</b>	<b>21.0%</b>	<b>18.8%</b>



# Economics of Bottoming Cycles for Large Diesel Generation Stations

- **Capital Costs:**
  - Kalina Cycle<sup>®</sup> less than Rankine Bottoming Cycle (\$/kW)
  - Kalina Cycle<sup>®</sup> more than diesel generation power plant
- **Savings in fuel cost more than makes up for additional capital**
  - Savings on fuel is dependent upon fuel type
- **Include impact of standby diesel generation capacity for frequent diesel unit maintenance**





# **Economic Viability of Adding Kalina Bottoming Cycle to Existing Diesel Generation Station:**


- **Size of the Diesel Station**
- **Number and Capacity of Each Diesel Unit**
- **Diesel Unit Annual Average Capacity Factor**
- **Diesel Unit Exhaust Heat Rejection**
- **Capital Cost of the Kalina Bottoming Cycle Power Plant**
- **Avoided Cost of Energy (Purchased Energy Tariff or cost of fuel and O&M)**
- **Kalina Cycle Power Plant O&M**
- **Escalation Assumptions**
- **Discount Rate or Cost of Capital**
- **Debt Assumptions**
- **Tax Assumptions**





# Diesel Generation Combined Cycle Screening Criteria

Chart 1: DG Combined Cycle Screening Criteria



# Coal Burning Facilities



**AES Hawaii, Inc. - Oahu**





# Biomass/Waste Power Plants

Courtesy: HECO

**Biomass Power Plant – Maui**



**H-Power Plant – Oahu  
(Waste)**

Courtesy: HECO



# Large Industrial Facilities

Courtesy: Tesoro

**Tesoro Refinery - Oahu**



**Tesoro Power Plant - Oahu**

Courtesy: Tesoro



# Geothermal Power Plants

**Puna Geothermal Venture - Hawaii**



Courtesy: HECO




**Recent Lava Flow - Hawaii**

Courtesy: HECO






# Schematic of the Puna Geothermal Venture Facility



# Simple Schematic of Binary Cycle in Geothermal Configuration

**Binary Cycle Power Plant**



2/24/2018



# Husavik/Puna Resource Comparison


**Husavik:**            **Brine Flow - 90 l/s @ 121 °C**  
                         **CW Flow – 180 l/s @ 4 °C**  
                         **Power Generated = 1.7 MW<sub>net</sub>**  
                         **Total Cost \$1,875,000 (\$905/kW)**

**Puna:**                **Brine Flow – ~189 l/s @ 149 °C**  
                         **CW Flow - ~85 l/s @ 40.6 °C**

**Air Cooling? Ocean Water?**



# Used in Conjunction with Local Power Plant and Seawater Air Conditioning (SWAC) Facility




# Providing the Power Cycle for OTEC Applications!



# Greatest Potential for Hawaii Kalina Cycle®

Applications:

OTEC



# Predicted Heat Rate/Efficiency Gains by Power Plant Technology

- **Geothermal Plants:** ~ 30 – 50 %
- **Coal/Biomass/  
Waste Plants:** ~ 20%
- **Diesel/  
Petroleum Plants:** ~ 10 – 15%
- **OTEC Plants:** ~ 50 + %





# Conclusions:

- **Kalina Cycle<sup>®</sup> is Superior Technology to Traditional Rankine Cycle for Low Temperature/Bottoming Cycle Applications**
- **Hawaii has Significant Waste Heat Resources for Potential Kalina Cycle<sup>®</sup> Integration**
- **Integration Makes Good Environmental and Economic Sense Under Amenable Conditions**
- **Further Analysis for Specific Identified Applications is Warranted**

